



NOTES:

1. AN APPROVED BACK FLOW ASSEMBLY SHALL BE INSTALLED BETWEEN THE NEW AND EXISTING WATERLINES DURING DISINFECTION AND FLUSHING OF NEW WATER MAIN.
2. THE BACK FLOW PREVENTION ASSEMBLY AND SUPPLY HOSE MUST BE DISCONNECTED DURING HYDROSTATIC PRESSURE TESTING OF THE NEW MAIN.
3. THE NEW WATER MAIN SHALL BE CONNECTED TO THE EXISTING SYSTEM ONLY AFTER THE NEW MAIN IS FLUSHED, DISINFECTED AND SATISFACTORY BACTERIOLOGICAL SAMPLE RESULTS ARE OBTAINED.
4. THE INTERIORS OF ALL PIPES AND FITTINGS TO BE USED IN FINAL CONNECTION MUST BE SWABBED OR SPRAYED WITH A 1% AVAILABLE CHLORINE SOLUTION.
5. 2" HYDRANT METER SHALL BE OBTAINED FROM THE CITY OF WENATCHEE PUBLIC WORKS DEPARTMENT OR CHELAN COUNTY PUD HYDRANT VALVE MAY BE USED UNDER SOME CIRCUMSTANCES.
6. DECHLORINATOR REQUIRED, CONTRACTOR MAY FLUSH TO SEWER OR STORM AFTER USING DECHLORINATOR. NOTIFY WENATCHEE WASTE WATER TREATMENT PLANT PRIOR TO FLUSH AIR GAP AT DISCHARGE.

STANDARD DETAIL

FILLING NEW

WATER MAINS



SCALE: AS SHOWN	DATE DRAWN		REVISIONS	
	11/04/2020		DATE	INITIAL
			01/22	AJS
	DESIGNED	CHECKED		
APPROVED BY		DATE APPROVED		
STANDARD SPECIFICATIONS				
DETAIL NO. W-110				
PAGE 1 OF 1				